

10. SEWER REPORT:

SEWER DEPARTMENT

Installed rain guards on Jefferson.

Utilizing the Camera and Vactor, cleaned main sewer line on Edith from Idaho up to Hilltop due to stone being in the main line. S&E Utility has been notified by letter, and at the New Kensington's Municipal Water Authority's monthly Waterline Replacement Meeting. Replaced #1 contactor and new suction flange at Indian Fields Pump Station. Replaced solenoid on #1 vacuum line at Craigdell Pump Station. Replaced Pump #1 at Little Braeburn, Hillcrest, and Widmer Pump Stations. Along with a 2' piece of vertical discharge pipe in the dry well at Widmer. Replaced Bushing and reset suction pipe at Indian Fields after cleaning with the Vactor. Root cutted Montana R/W and utilized camera with locators to verify depth of a buried MH. Replaced universal joint, impeller, and back flush at Widmer Pump Station. Ran camera evaluations on Garvers Ferry, Clinton, and Craigdell Road storm lines. Performed sewer lateral inspections at 10 Nanak Drive, 174 Oakridge, 259 Oakridge Drive, 269 Oakridge Drive, 1721 Wildlife Lodge Road, 1743 Wildlife Lodge Road, 1809 Wildlife Lodge, 2793 Gravatt Way, and 1746 Rose Street. Parged/Sealed manhole on Short Street R/W.

Demonstrations on sewer locators were performed by Vendors for the Sewer Dept.

Cut grass at Pump Stations when needed. Evaluated main sewer line from Illinois to Craigdell Road with the sewer camera. Checked, cleaned, and greased pump stations; cleaned floats and checked grinders; performed end of month cleaning. Located manhole on Spooky Hollow R/W and marked line for a new home construction. Continued to perform vehicle maintenance. Aided Street Dept. in locating gas lines, water lines, and for setting a new catch basin on Edgeview. Performed PA One Calls as needed. Put 2 loads of stone on landscape plastic for resident at Hillcrest Estates Pump Station. Conducted monthly Safety Inspections of all Pump Stations. Scott Johnson & Bill Thomey attended the Three Rivers Wet Weather Conference in Monroeville on October 7 and 8, 2015. Sewer Department Personnel attended a MS4 Workshop hosted by the PA DEP in Allegheny Township on October 20, 2015. Eric Haser attended the City Hall Safety Meeting.

Hillcrest Country Club is checking out why there is so much I & I entering their lateral. No answer as of yet.

11. ENGINEER'S REPORT:

PROJECT STATUS REPORT

1. **Contract 13-1& 13-2 (Interceptor Replacement & Wildlife Lodge Road Area Collection System) Wildlife Lodge Road Area Sanitary Sewer Extension**

The notice of termination paperwork has started. WCCD must still perform their final inspection. There is one area from PENNDOT's inspection on Wildlife Lodge Rd that needs addressed. This will be done in spring 2016. The final grant payment from EPA to LBMA is \$80,000 which is \$24,000 more than expected. This money was applied for by Ed Bloch.

2. **Contract 13-3**

Widmer, Indiana, and Hillcrest Pump Station Elimination Project

The Westmoreland Conservation District must complete their final inspection. The Mendone refund due to the LBMA and the Maintenance Bond were mailed to Alpha Engineering.

4. **Long Term Control Plan (LTCP)**

The City and Authority met with PennVest to discuss future funding. Research and pricing was done on Costars for sanitary sewer rehabilitation.

11. SOLICITOR'S REPORT:

The solicitor received take or leave it letters from Jim Kopelman concerning the Willow Grant property and the four residents from the Indian pump station project. this was approved..

GO TO EXECUTIVE SESSION: Motion:_____GA_____ Second:_____TA_____

RETURN TO BOARD MEETING: Motion:___TA_____ Second:_____GA_____

MEETING ADJOURN: Motion:_____TA_____ Second:___KL_____

NEXT MEETING: TUESDAY, DECEMBER 15, 2015 - 6:30 P.M.